

TAX INVOICE
Landis+Gyr Limited
ಲ್ಯಾಂಡಿಸ್ + ಗೈರ್ ಲಿಮಿಟೆಡ್

Landis+Gyr

R. O.
No. 503, 3rd Main,
50 Feet Road, Srinagar,
Bangalore - 560 050

Branch Office
O/o Asst. Executive Engineer Elec.,
N 4 Sub Division, BESCOM Office Compound,
Bangalore Electricity Supply Company Limited
14th Cross, Peenya 2nd Stage,
Bangalore - 560 058.

Name AEE BBMP
Address T. D. Halli
N-15 Sub Division
Prashanthnagar Bldg

BILL No. **PNY** **58732**

DATE: 16/7/16 TIME: AM/PM

TIN : 29330352183
CST No. 01153900 Dt. 10-03-2003

Sl. No.	Description	Quantity	Rate per Pc Rs.	Value Amount Rs.	P.
	Single Phase Static Energy Meter Type : E150, 5-30 Amps Sl. Nos. <u>3phas</u> <u>C220708</u>	<u>01</u>	<u>1650.00</u>	<u>1650.00</u>	
Name of Company <u>BESCOM</u> DVN. <u>N5</u>		VAT @ <u>14.5%</u>		<u>239.25</u>	
W.O. No. <u>D-11747</u> Date <u>16/7/16</u>		GRAND TOTAL		<u>1889.25</u>	

E.&O.E.

For Landis+Gyr Limited.

Bangalore Electricity Supply Company Limited

No.: BESCOM/NC_LTPWRSA/6655292034/16-07-2016

Office of
The Assistant Executive Engineer
N5 SRS GATE, BESCOM,
DATE: 16-07-2016

To,
A E E (BBMP T. DASARAHALLI SUB-DIVISION),
WARD NO 15 5TH CROSS PAMPA MAHA KAVI ROAD PRASHANTH NAGAR

KARNATAKA
560057

Sir/Madam,

Sub: Arranging LT power supply-NEW CONNECTION

Ref: 1) Application No:700717342597 Dated: 14-07-2016
2) Account ID : 8555295634
3) Prevailing KERC regulations.

With reference to your Application No. **700717342597 Dated: 14-07-2016**, power supply to an extent of **0 KW** and **10 HP** on Account ID **8555295634** under LT basis, is hereby sanctioned, subject to the following:

1. Details of your building/premises:

a. Plinth area:


1	No. of Floors Existing	0
2	No. of Floors Added or New	0
3	Existing Plinth Area in sq.m.	0
4	Added or New Plinth Area in sq.m.	0
5	Total Plinth Area in sq.m.	0

b. Total height of the building above ground level in m: 0

2. The **PROPOSED** Sanctioned Load of your building is **7.46 KW**

Existing Load Details of your premises:

1	Existing Sanctioned Load	0
2	New/ Additional Load Required	0 KW and 10 HP
3	Total Load	7.46 KW

You are requested to pay the following charges by Cash/ DD (above ₹10000/-, only DD will be accepted) in favour of The Assistant Executive Engineer (EI) **N5 SRS GATE, BESCO** within **90** days from the date of this letter:

Sl. No.	Particulars	Amount
1.	Initial Security Deposit (ISD)	₹7400.00
2.	Service Line charges (Development Charges)	₹0.00
3.	Additional Service Line charges (Additional Development Charges)	₹0.00
4.	Infrastructure charges	₹0.00
5.	10 % Supervisory Charges	₹0
Total		₹7400.00

Note: 2 MMD/MSD shall be paid separately for individual installations (separate Payment Receipts to be drawn).

3. The power supply will be arranged at 400V

4. The Power Tariff applicable to your proposed installation will be **Monthly LT6A tariff schedule for metered customers(BESCO)** Tariff, or as in force from time to time

5. You have to confirm to purchase High precision/Electrostatic meters/ETV meters of the following capacity:

a) Single Phase Meters 1 Nos.

b) Three Phase Meters 0 Nos.

c) ETV Meters 0 Nos.

d) TP box with CTR Nos.

6. After the payments, the following requirements may please be fulfilled:

a) Execute agreement of power supply on ₹200/- Stamp Paper in duplicable, for individual installations in the prescribed format

b) Produce necessary License/Permit/No Objection Certificate etc., issued by the Competent Authority, as required under the statute

7(a) The Power supply will be arranged by **BESCO** as below:

a) From the existing KVA Transformer

b) After enhancement of TC capacity from KVA to 0 KVA of the TC located at

c) After erecting new 0 KVA transformer under service connection

7(b) If you intend to install distribution transformer inside your premises, and execute the work under self-execution, to avail above power supply, the following shall be complied:

- An electrical room with RCC roof having clear floor area of 5 metres X 4 metres, with a vertical clearance of 2.75 metres with locking facility, exhaust fans and adequate size of cable duct, shall be provided at the ground floor, within the Applicant's premises nearer to the main entrance, for installing floor mounted distribution transformer and associated switchgear, or
- A clear space of 3 metres X 5 metres open to the sky shall be provided, within the Applicant's premises, preferably at the main entrance, for installing structure mounted distribution transformer and switchgear

8. **BESCO** approved suitable capacity circuit breaker, ELCB & switchgears shall be used, and all the provisions under KERK Regulations 4.03 and 4.04 shall be complied

9. **BESCO** reserves the right to cancel power supply and forfeiting of the Deposits paid by you, if the documents submitted by you are found to be fake

10. As per the Govt. Order, solar water heaters of suitable capacity shall be provided

nos. of Compact Fluorescent Lamps shall be used for each installation
metering equipment to be installed should be conspicuously visible and at the main entrance to the
ises, preferably with an independent entrance
ou are requested to contact the undersigned in case of any other information that may be required by you.
We remain at your services.


Yours faithfully,

Assistant Executive Engineer

 **N5 SRS GATE, BESCOM**